

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0450:106 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: LCN Closer, 121 Railroad Avenue, Princeton, IL 61356
Contact: *Ruth Gallianetti (815) 875-3311 Fax (815) 879-1495

DESIGN: SENTRONIC Models 4040 SE, 4040 SEC, and 4040 SED door closer/holders with or without smoke detector. Model 4040 SED employs an integral smoke detector. Model 4040 SEC is an SED device without the smoke detector and is intended for use as a companion unit to Model 4040 SED on pairs of doors. The detector in the 4040 SED releases holding unit in both Models 4040 SED and 4040 SEC simultaneously. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door closer/holders (with or without integral smoke detector) for swinging type fire doors when used in conjunction with separately listed compatible smoke detectors or fire alarm control units.

*Rev. 06-09-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**